


No. P05204552

Order No. 15773

| | |
|---|---|
| Applicant | DEVI A/S Ulvehavevej 61 DK-7100 Vejle DENMARK |
| Manufacturer | DEVI A/S Ulvehavevej 61 DK-7100 Vejle DENMARK |
| Factory | DEVI A/S Bødkervej 8 DK-7100 Vejle DENMARK |
| Group | Automatic electrical controls. |
| Model/type | WEB-HOME |
| Data | Supply: 24V DC SELV. Load: 2A 250V AC |
| Trade mark | DEVI |
| Other specification | Gateway for control of thermostats for DIN-rail mounting. Type 1.B action, micro-disconnection, 1E5 automatic cycles, overvoltage category III, pollution degree II, category D, PTI 175, Class III, with pillar terminals. IP20. |
| The above product is certified according to the following standard(s) | Safety std.: EN 60730-1:2000 + A11:2002 + A12:2003 + A1:2004 + A13:2004 + A15:2005 + OSM/IN decisions. |
| Validity | This certificate documents conformity with the standards shown, and also applies as license for use of Nemko's name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary. |

Date of issue 10 June 2005


signatureRagnar Køltzow
Certification Department